

FEB 12 2013

**DIVISION OF THE STATE FIRE MARSHALL  
BUREAU OF FIRE PREVENTION  
BOILER SAFETY PROGRAM**

This inspection is intended for your safety and the safety of the citizens of Florida. Your cooperation is greatly appreciated.

**Boiler - Fired Pressure Vessel report of Inspection**

Date Inspected <b>02/05/2013</b>	Cert. Exp Date <b>02/05/2014</b>	Certificate Posted <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Follow Up Inspection <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Jurisdiction Number <b>015166</b>	Nat'l Rd No <b>5167</b>	Other No <b>Hollywood</b>
Owner <b>Hollywood Studio Theme Park</b>		Nature Of Business <b>Amusement and Recreation</b>		Kind of Inspection <input checked="" type="checkbox"/> Int <input type="checkbox"/> Ext		Cert Inspection <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Owner Street Address <b>271 N World Drive</b>		Owner City <b>Lake Buena Vista</b>		State <b>FL</b>	Zip <b>32830</b>	
User Name - Object Location <b>Hollywood Studio Theme Park</b>		Specific Location in Plant <b>Epic Theatre</b>		Object Location - County <b>Orange</b>		
User Street Address <b>271 N World Dr.</b>		User City <b>Lake Buena Vista</b>		State <b>FL</b>	Zip <b>32830-1000</b>	
Type <b>Fire Tube</b>		Year Built <b>1998</b>	Manufacturer <b>Hurst</b>			
Use <b>Process</b>		Fuel <b>Natural Gas</b>	Method of Firing <b>Automatic</b>		Pressure Gage Tested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Pressure <b>Allowed</b>	This Inspection <b>150</b> psi	Prev. Inspection <b>150</b> psi	Safety Relief Valves Set At <b>150</b> psi	Total Capacity <b>1651 LB/HR</b>	Heating Surface and/or BTU <b>55 sq ft</b>	
Is condition of object such that a certificate may be issued? (If No, explain fully under condition)				Hydro Test <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
<p><b>CONDITIONS:</b> With respect to the internal surface, describe and state location of any scale, oil or other deposits. Give location and extent of any corrosion and state whether active or inactive. State location and extent of any erosion, grooving, bulging, warping, cracking or similar condition. Report on any defective rivets, bowed, loose or broken stays. State condition of all tubes, tube ends, coils, nipples, etc. Describe any adverse conditions with respect to pressure gage, water column, gage glass, gage cocks, safety valves, etc. Report conditions of setting, linings, baffles, supports, etc. Describe any major changes or repairs made since last inspection.</p> <p><b>The boiler was in satisfactory condition at this internal inspection. Note: new McDonnell miller float chamber and replacement secondary LWC probe installed.</b></p>						
<p><b>REQUIREMENTS:</b> (List of Code Violations)</p> <p><b>None Required</b></p>						
Name and Title of Person To Whom Requirements Were Explained Mr. Jim Audet, Planned Work Specialist						
I HEREBY CERTIFY THIS IS A TRUE REPORT OF MY INSPECTION <i>Richard L Mork</i>						
Inspector Name <b>Richard L Mork</b>		Ident. No. <b>FL-555 NB-9759 A</b>		Employed By <b>FM Global</b>		Ident. No. <b>30199775</b>

D14-379

10/01/2000