

**DIVISION OF THE STATE FIRE MARSHALL
BUREAU OF FIRE PREVENTION
BOILER SAFETY PROGRAM**

SEP 10 2013

This inspection is intended for your safety and the safety of the citizens of Florida. Your cooperation is greatly appreciated.

Boiler - Fired Pressure Vessel report of Inspection

Date Inspected 08/24/2013	Cert. Exp Date	Certificate Posted <input type="checkbox"/> Yes <input type="checkbox"/> No	Follow Up Inspection <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Jurisdiction Number 018817	Nat'l Bd No 11405	Other No 13339
Owner Hyatt			Nature Of Business Hotels and Motels		Kind of Inspection <input checked="" type="checkbox"/> Int <input type="checkbox"/> Ext	
Owner Street Address 1 Grand Cypress Blvd			Owner City Orlando		State FL	
User Name - Object Location Kyo-Ya Company, Ltd.			Specific Location in Plant steam boiler room		Object Location - County Orange	
User Street Address 1 Grand Cypress Blvd			User City Orlando		State FL	
Type Fire Tube			Year Built 2009		Manufacturer sellers	
Use Process			Fuel Natural Gas		Method of Firing Automatic	
Pressure Allowed 150 psi			Prev. Inspection 150 psi		Safety Relief Valves Set At 150 psi	
Total Capacity 4234 LB/HR			Heating Surface and/or BTU 138 sq ft / 2768000 BTU/hr			
Is condition of object such that a certificate may be issued? (If No, explain fully under condition)					Hydro Test <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
					PSI DATE <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
<p>CONDITIONS: With respect to the internal surface, describe and state location of any scale, oil or other deposits. Give location and extent of any corrosion and state whether active or inactive. State location and extent of any erosion, grooving, bulging, warping, cracking or similar condition. Report on any defective rivets, bowed, loose or broken stays. State condition of all tubes, tube ends, coils, nipples, etc. Describe any adverse conditions with respect to pressure gage, water column, gage glass, gage cocks, safety valves, etc. Report conditions of setting, linings, baffles, supports, etc. Describe any major changes or repairs made since last inspection.</p>						
<p>REQUIREMENTS: (List of Code Violations)</p> <p>None Required</p>						
Name and Title of Person To Whom Requirements Were Explained Mr. Forero, Enrique						
I HEREBY CERTIFY THIS IS A TRUE REPORT OF MY INSPECTION <i>Rashad Morris</i>						
Inspector Name Rashad Morris			Ident. No. FL-1736 NB-14574		Employed By FM Global	
					Ident. No. 30199775	

**D14-379
10/01/2000**