

**DIVISION OF THE STATE FIRE MARSHALL
BUREAU OF FIRE PREVENTION
BOILER SAFETY PROGRAM**

RECEIVED

JAN 31 2014

This inspection is intended for your safety and the safety of the citizens of Florida. Your cooperation is greatly appreciated.

Boiler - Fired Pressure Vessel report of Inspection

**Bureau of
Fire Prevention**

Date Inspected 01/23/2014	Cert. Exp Date	Certificate Posted <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Follow Up Inspection <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Jurisdiction Number 015166	Natl Rd No 5167	Other No Hollywood
Owner Hollywood Studio Theme Park			Nature Of Business Amusement and Recreation		Kind of Inspection <input checked="" type="checkbox"/> Int <input type="checkbox"/> Ext	
Owner Street Address 271 N World Drive			Owner City Lake Buena Vista		State FL	
User Name - Object Location Hollywood Studio Theme Park			Specific Location in Plant Epic Theatre		Object Location - County Orange	
User Street Address 271 N World Dr.			User City Lake Buena Vista		State FL	
Type Fire Tube			Year Built 1998		Manufacturer Hurst	
Use Process			Fuel Natural Gas		Method of Firing Automatic	
Pressure Allowed 150 psi			Prev. Inspection 150 psi		Safety Relief Valves Set At 150 psi	
Total Capacity 1651 LB/HR			Heating Surface and/or BTU 55 sq ft		Pressure Gage Tested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Is condition of object such that a certificate may be issued? (If No, explain fully under condition)						Hydro Test <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
<p>CONDITIONS: With respect to the internal surface, describe and state location of any scale, oil or other deposits. Give location and extent of any corrosion and state whether active or inactive. State location and extent of any erosion, grooving, bulging, warping, cracking or similar condition. Report on any defective rivets, bowed, loose or broken stays. State condition of all tubes, tube ends, coils, nipples, etc. Describe any adverse conditions with respect to pressure gage, water column, gage glass, gage cocks, safety valves, etc. Report conditions of setting, linings, baffles, supports, etc. Describe any major changes or repairs made since last inspection.</p> <p>boiler satisfactory</p>						PSI DATE
<p>REQUIREMENTS: (List of Code Violations)</p> <p>None Required</p>						
Name and Title of Person To Whom Requirements Were Explained Mr. Jim Audet, planned work specialist						
I HEREBY CERTIFY THIS IS A TRUE REPORT OF MY INSPECTION <i>Richard L Mork</i>						
Inspector Name Richard L Mork		Ident. No. FL-555 NB-9759 A		Employed By FM Global		Ident. No. 30199775

D14-379

10/01/2000