

**DIVISION OF THE STATE FIRE MARSHALL  
BUREAU OF FIRE PREVENTION  
BOILER SAFETY PROGRAM**

This inspection is intended for your safety and the safety of the citizens of Florida. Your cooperation is greatly appreciated.

**Boiler - Fired Pressure Vessel report of Inspection**


Date Inspected <b>09/02/2014</b>	Cert. Exp Date	Certificate Posted <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Follow Up Inspection <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Jurisdiction Number <b>018817</b>	Nat'l Rd. No. <b>11405</b>	Other No. <b>13339</b>
Owner <b>Hyatt</b>			Nature Of Business <b>Hotels and Motels</b>		Kind of Inspection <input checked="" type="checkbox"/> Int <input type="checkbox"/> Ext	Cert Inspection <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Owner Street Address <b>1 Grand Cypress Blvd</b>			Owner City <b>Orlando</b>		State <b>FL</b>	Zip <b>32836-6734</b>
User Name - Object Location <b>Kyo-Ya Company, Ltd.</b>			Specific Location in Plant <b>steam boiler room</b>		Object Location - County <b>Orange</b>	
User Street Address <b>1 Grand Cypress Blvd</b>			User City <b>Orlando</b>		State <b>FL</b>	Zip <b>32836-6734</b>
Type <b>Fire Tube</b>		Year Built <b>2009</b>	Manufacturer <b>sellers</b>			
Use <b>Process</b>			Fuel <b>Natural Gas</b>	Method of Firing <b>Automatic</b>	Pressure Gage Tested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Pressure <b>Allowed</b>	This Inspection <b>150</b> psi	Prev. Inspection <b>150</b> psi	Safety Relief Valves Set At <b>150</b> psi	Total Capacity <b>4234 LB/HR</b>	Heating Surface and/or BTU <b>138 sq ft / 2768000 BTU/hr</b>	
Is condition of object such that a certificate may be issued? (If No, explain fully under condition)				Hydro Test <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No <input type="checkbox"/> Yes _____ PSI DATE _____ <input checked="" type="checkbox"/> No		

**CONDITIONS:** With respect to the internal surface, describe and state location of any scale, oil or other deposits. Give location and extent of any corrosion and state whether active or inactive. State location and extent of any erosion, grooving, bulging, warping, cracking or similar condition. Report on any defective rivets, bowed, loose or broken stays. State condition of all tubes, tube ends, coils, nipples, etc. Describe any adverse conditions with respect to pressure gage, water column, gage glass, gage cocks, safety valves, etc. Report conditions of setting, linings, baffles, supports, etc. Describe any major changes or repairs made since last inspection.

**Inspection completed satisfactory; no recommendations at this time.**

**REQUIREMENTS:** (List of Code Violations)

**None Required**



Name and Title of Person To Whom Requirements Were Explained  
Forero, Enrique - Director of Engineering - Hyatt - (ph)407 239-3844

**I HEREBY CERTIFY THIS IS A TRUE REPORT OF MY INSPECTION**

*Rashad Morris*

Inspector Name	Ident. No.	Employed By	Ident. No.
<b>Rashad Morris</b>	<b>FL-1736 NB-14574</b>	<b>FM Global</b>	<b>30199775</b>

**D14-379  
10/01/2000**