

**DIVISION OF THE STATE FIRE MARSHALL
BUREAU OF FIRE PREVENTION
BOILER SAFETY PROGRAM**

This inspection is intended for your safety and the safety of the citizens of Florida. Your cooperation is greatly appreciated.

Boiler - Fired Pressure Vessel report of Inspection


Date Inspected 10/12/2016	Cert. Exp Date	Certificate Posted <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Follow Up Inspection <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Jurisdiction Number 018817	Natl Bd. No. 11405	Other No. 13339
Owner Hyatt	Nature Of Business Hotels and Motels			Kind of Inspection <input checked="" type="checkbox"/> Int <input type="checkbox"/> Ext	Cert Inspection <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Owner Street Address 1 Grand Cypress Blvd			Owner City Orlando	State FL	Zip 32836-6734	
User Name - Object Location Hyatt Regency Grand Cypress			Specific Location in Plant steam boiler room		Object Location - County Orange	
User Street Address 1 Grand Cypress Blvd			User City Orlando	State FL	Zip 32836-6734	
Type Fire Tube		Year Built 2009	Manufacturer sellers			
Fuel Natural Gas			Method of Firing Automatic	Pressure Gage Tested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Pressure Allowed	This Inspection 150 psi	Prev. Inspection 150 psi	Safety Relief Valves Set At 150 psi	Total Capacity 4234 LB/HR	Heating Surface and/or BTU 138 sq ft / 2768000 BTU/hr	

Is condition of object such that a certificate may be issued?
(If No, explain fully under condition) Yes No

Hydro Test Yes No PSI DATE _____

CONDITIONS: With respect to the internal surface, describe and state location of any scale, oil or other deposits. Give location and extent of any corrosion and state whether active or inactive. State location and extent of any erosion, grooving, bulging, warping, cracking or similar condition. Report on any defective rivets, bowed, loose or broken stays. State condition of all tubes, tube ends, colls, nipples, etc. Describe any adverse conditions with respect to pressure gage, water column, gage glass, gage cocks, safety valves, etc. Report conditions of setting, linings, baffles, supports, etc. Describe any major changes or repairs made since last inspection.

REQUIREMENTS: (List of Code Violations)
None Required



Name and Title of Person To Whom Requirements Were Explained
Enrique Forero

I HEREBY CERTIFY THIS IS A TRUE REPORT OF MY INSPECTION
Harold F Bowers

Inspector Name Harold F Bowers	Ident. No. FL-535 NB-12485	Employed By FM Global	Ident. No. 30199775
-----------------------------------	-------------------------------	--------------------------	------------------------

D14-379
10/01/2000