

**DIVISION OF THE STATE FIRE MARSHALL  
BUREAU OF FIRE PREVENTION  
BOILER SAFETY PROGRAM**

This inspection is intended for your safety and the safety of the citizens of Florida. Your cooperation is greatly appreciated.

**Boiler - Fired Pressure Vessel report of Inspection**

Date Inspected* <b>04/10/2018</b>	Cert. Exp Date*	Certificate Posted <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Follow Up Inspection* <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Jurisdiction Number * <b>132508</b>	Nat'l Rd. No. <b>20882</b>	Other No.	
Owner <b>Lake Tribe Brewing LLC</b>			Nature Of Business <b>Manufacturer</b>		Kind of Inspection <input type="checkbox"/> Int <input checked="" type="checkbox"/> Ext		Cert Inspection <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Owner Street Address <b>3357 Garber Dr Unit 4</b>			Owner City <b>Tallahassee</b>		State <b>fl</b>	Zip <b>32303-1123</b>	
User Name - Object Location <b>Lake Tribe Brewing LLC</b>			Specific Location in Plant <b>Outside</b>		Object Location - County <b>Leon</b>		
User Street Address <b>3357 Garber Dr Unit 4</b>			User City <b>Tallahassee</b>		State <b>FL</b>	Zip <b>32303-1123</b>	
Type * <b>Fire Tube</b>			Year Built <b>2015</b>	Manufacturer <b>Hurst</b>			
Use <b>Process</b>			Fuel <b>Natural Gas</b>	Method of Firing <b>Automatic</b>	Pressure Gage Tested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Pressure Allowed <b>15</b>	This Inspection <b>15</b>	psi	Prev. Inspection <b>15</b>	psi	Safety Relief Valves Set At <b>15</b>	psi	Total Capacity <b>3164 LB/HR</b>
						Heating Surface and/or BTU <b>55 sq ft / 518000 BTU/hr</b>	

Is condition of object such that a certificate may be issued? \*  
(If No, explain fully under condition) ☐ Yes ☒ No

Hydro Test ☐ Yes ☒ No PSI DATE ☒ No

**CONDITIONS:** With respect to the internal surface, describe and state location of any scale, oil or other deposits. Give location and extent of any corrosion and state whether active or inactive. State location and extent of any erosion, grooving, bulging, warping, cracking or similar condition. Report on any defective rivets, bowed, loose or broken stays. State condition of all tubes, tube ends, coils, nipples, etc. Describe any adverse conditions with respect to pressure gage, water column, gage glass, gage cocks, safety valves, etc. Report conditions of setting, linings, baffles, supports, etc. Describe any major changes or repairs made since last inspection.

**ASME "H" Pre internal inspection. – FL 9.3.2 Boiler requires an internal inspection.**

**REQUIREMENTS:** (List of Code Violations)

**Boiler number FL 132508 is due for an internal inspection. Florida Statutes 554.108 requires all low pressure steam boilers to have the internal watersides and firesides inspected biennially. The boiler inspector should be consulted with prior to the internal inspection in order to satisfy all of the requirements. At a minimum, the boiler should be drained of all liquid, purged of any toxic or flammable gases, and have all openings to the water side opened for easy access and inspection. The fire side of the boiler should be opened to the extent that entry or a good visual inspection can be made. The low water fuel cutoff must be opened for examination of the internal parts such as float assembly and chamber and probes, as well as the wiring for the controls. The boiler and surrounding area should be clean with provisions for safe access. All sources of potential energy must be isolated as well as locked and tagged. This inspection should be scheduled and conducted within the next 45 days.**

Name and Title of Person To Whom Requirements Were Explained  
Jesse Ross/Owner/850222-8100

**I HEREBY CERTIFY THIS IS A TRUE REPORT OF MY INSPECTION**

Inspector Name <b>Michael Barnhart</b>	Ident. No. <b>FL-12-000020 NB-12822</b>	Employed By <b>Travelers</b>	Ident. No. <b>30199797</b>
---	--	---------------------------------	-------------------------------

**D14-379  
10/01/2000**