



**DIVISION OF STATE FIRE MARSHAL
BUREAU OF FIRE PREVENTION
BOILER SAFETY PROGRAM**

**Boiler-Fired Pressure Vessel
REPORT OF INSPECTION**

This inspection is intended for your safety and the safety of the citizens of Florida. Your cooperation is greatly appreciated.

DATE INSPECTED 02/17/2020	CERT EXP DATE	CERT POSTED <input checked="" type="radio"/> Yes <input type="radio"/> No	FOLLOW UP ? <input type="radio"/> Yes <input checked="" type="radio"/> No	JURISDICTION NUMBER FL019808	NATL BOARD NO 12569	OTHER NO
OWNER BayCare Health Systems, Inc			NATURE OF BUSINESS HOSPITALS		KIND OF INSP. <input checked="" type="radio"/> INT <input type="radio"/> EXT	CERT INSP ? <input checked="" type="radio"/> Yes <input type="radio"/> No
OWNER STREET ADDRESS 1200 7th Avenue MS 2053			OWNERS CITY St. Petersburg		STATE FL	ZIP 33705
USER NAME - OBJECT LOCATION ST. ANTHONY'S HOSPITAL			SPECIFIC LOCATION IN PLANT BOILER ROOM		OBJECT LOCATION - COUNTY PINELLAS	
LOCATION STREET ADDRESS 1200 7TH AVE N			LOCATION CITY ST PETERSBURG		STATE FL	ZIP 33705
TYPE <input checked="" type="checkbox"/> FT <input type="checkbox"/> WT <input type="checkbox"/> CI <input type="checkbox"/> OTHER		YEAR BUILT 2003		MANUFACTURER CLEAVER BR		
USE <input type="checkbox"/> POWER <input checked="" type="checkbox"/> PROCESS <input type="checkbox"/> STM HTG <input type="checkbox"/> HWH <input type="checkbox"/> HWS <input type="checkbox"/> OTHER			FUEL Natural Gas		METHOD OF FIRING Burner	PRESSURE TESTED <input type="radio"/> Yes <input checked="" type="radio"/> No
PRESSURE ALLOWED THIS INSPECTION 150 PREV INSP 150		SAFETY - RELIEF VALVES SET AT 90 TOTAL CAPACITY 8,382,000 BTUs			OBJECT CAPACITY 6,900,000 BTUs	
IS CONDITION OF OBJECT SUCH THAT A CERTIFICATE MAY BE ISSUED ? <input checked="" type="radio"/> Yes <input type="radio"/> No (IF NO EXPLAIN FULLY UNDER CONDITIONS)				HYDRO TEST <input type="radio"/> Yes <input checked="" type="radio"/> No PSI Date		

CONDITIONS: With respect to the internal surface, describe and state location of any scale, oil or other deposits. Give location and extent of any corrosion and state whether active or inactive. State location and extent of any erosion, grooving, bulging, warping, cracking or similar condition. Report on any defective rivets, bowed, loose or broken stays. State condition of all tubes, tube ends, coils, nipples, etc. Describe any adverse conditions with respect to pressure gage, water column, gage glass, gage cocks, safety valves, etc. Report condition of setting, linings, baffles, supports, etc. Describe any major changes or repairs made since last inspection.

NO ADVERSE CONDITIONS NOTED.

REQUIREMENTS: (List Code Violations)

NONE

NAME AND TITLE OF PERSON TO WHOM REQUIREMENTS WERE EXPLAINED

BILL SHUMAKER

CONTACT PHONE (727) 298-6000

THEREBY CERTIFY THIS IS A TRUE REPORT OF MY INSPECTION

INSPECTOR NAME Daniel Humenick

SIGNATURE OF INSPECTOR

Daniel B. Humenick

IDENT. NO

0518

EMPLOYED BY

HARTFORD STEAM BOILER INSPECTION AND INSURANCE COMPANY 9265