


**DIVISION OF THE STATE FIRE MARSHALL
BUREAU OF FIRE PREVENTION
BOILER SAFETY PROGRAM**

This inspection is intended for your safety and the safety of the citizens of Florida. Your cooperation is greatly appreciated.

Boiler - Fired Pressure Vessel report of Inspection

Date Inspected 10/13/2020	Cert. Exp Date	Certificate Posted <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Follow Up Inspection <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Jurisdiction Number 132508	Nat'l Bd. No. 20882	Other No.	
Owner Lake Tribe Brewing LLC			Owner Email cross@architects-gca.com		Kind of Inspection <input checked="" type="checkbox"/> Int <input type="checkbox"/> Ext		Cert Inspection <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Owner Street Address 3357 Garber Dr Unit 4			Owner City Tallahassee		State fl	Zip 32303-1123	
User Name - Object Location Lake Tribe Brewing LLC			Nature Of Business Manufacturer		Object Location - County Leon		
User Street Address 3357 Garber Dr Unit 4			User City Tallahassee		State FL	Zip 32303-1123	
Type Fire Tube	ASME Code Stamp H	Year Built 2015	Manufacturer Hurst				
Specific Location in Plant Outside		Use Process	Fuel Natural Gas	Method of Firing Automatic	Pressure Gage Tested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		
Pressure Allowed 15	This Inspection psi	Prev. Inspection 15	psi	Safety Relief Valves Set At 15	psi	Total Capacity 3164 LB/HR	Heating Surface and/or BTU 55 sq ft / 518000 BTU/hr
Is condition of object such that a certificate may be issued? (If No, explain fully under condition)				<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No		Hydro Test <input type="checkbox"/> Yes _____ PSI DATE _____ <input checked="" type="checkbox"/> No	
<p>CONDITIONS: With respect to the internal surface, describe and state location of any scale, oil or other deposits. Give location and extent of any corrosion and state whether active or inactive. State location and extent of any erosion, grooving, bulging, warping, cracking or similar condition. Report on any defective rivets, bowed, loose or broken stays. State condition of all tubes, tube ends, coils, nipples, etc. Describe any adverse conditions with respect to pressure gage, water column, gage glass, gage cocks, safety valves, etc. Report conditions of setting, linings, baffles, supports, etc. Describe any major changes or repairs made since last inspection.</p> <p>- FL 9.1.3 Perform and document annual testing</p>							
<p>REQUIREMENTS: (List of Code Violations)</p> <p>There is no current documentation of periodic maintenance and testing of controls and safety devices for boiler number FL132508. Proper testing aids in the prevention of machinery damage and enhances personnel safety. Section CM-130 of the ASME Code CSD-1 requires that the owner or user of an automatically fired boiler system develop and maintain a formal system of preventive maintenance and testing. Tests must be conducted on a regular basis and the results recorded in a boiler log, maintenance record or service invoice. Always follow the manufacturer's instructions. Testing and maintenance must be performed by qualified technicians and the results forwarded to the inspector for review and archiving. Action should be taken to repair any device that does not operate properly.</p>							
Name and Title of Person To Whom Requirements Were Explained Mr. Ross/Owner/850-222-8100							
I HEREBY CERTIFY THIS IS A TRUE REPORT OF MY INSPECTION 							
Inspector Name Michael Barnhart		Ident. No. FL-0020 NB-12822		Employed By Travelers		Ident. No. 30199797	

**D14-379
10/01/2000**