

DIVISION OF THE STATE FIRE MARSHALL
BUREAU OF FIRE PREVENTION
BOILER SAFETY PROGRAM

This inspection is intended for your safety and the safety of the citizens of Florida. Your cooperation is greatly appreciated.

Boiler - Fired Pressure Vessel report of Inspection

Date Inspected 06/10/2021	Cert. Exp Date	Certificate Posted <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Follow Up Inspection <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Jurisdiction Number 136626	Nat'l Bd. No. 301780	Other No.
Owner InTown Suites			Owner Email tammy.church@intownsuites.com		Kind of Inspection <input type="checkbox"/> Int <input checked="" type="checkbox"/> Ext	Cert Inspection <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Owner Street Address 980 Hammond Dr Ste 500			Owner City Atlanta		State GA	Zip 30328-8186
User Name - Object Location InTown Suites			Nature Of Business Hotel		Object Location - County Orange	
User Street Address 1951 Central Florida Pkwy			User City Orlando		State FL	Zip 32837-9291
Type Water Tube	ASME Code Stamp H	Year Built 2020	Manufacturer Laars			
Specific Location in Plant Boiler Room		Use Hot Water Supply	Fuel Natural Gas	Method of Firing Automatic	Pressure Gage Tested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Pressure Allowed 160	This Inspection 160 psi	Prev. Inspection 160 psi	Safety Relief Valves Set At 125 psi	Total Capacity 2289000 BTU/HR	Heating Surface and/or BTU 52.6 sq ft / 526000 BTU/hr	

Is condition of object such that a certificate may be issued?
 (If No, explain fully under condition) ☐ Yes ☒ No

Hydro Test ☐ Yes ☒ No PSI DATE

CONDITIONS: With respect to the internal surface, describe and state location of any scale, oil or other deposits. Give location and extent of any corrosion and state whether active or inactive. State location and extent of any erosion, grooving, bulging, warping, cracking or similar condition. Report on any defective rivets, bowed, loose or broken stays. State condition of all tubes, tube ends, coils, nipples, etc. Describe any adverse conditions with respect to pressure gage, water column, gage glass, gage cocks, safety valves, etc. Report conditions of setting, linings, baffles, supports, etc. Describe any major changes or repairs made since last inspection.

External Inspection noted no evidence of leakage, distortion, bulging, overheating or any other detrimental conditions. Relief valve was tested manually by maintenance and functioned satisfactorily. ASME Code Stamp H. A Violation was issued for this boiler 7/23/2020by inspector John Kopetz for MDR and CSD-1.

REQUIREMENTS: (List of Code Violations)

None Required

Name and Title of Person To Whom Requirements Were Explained
 Jonathan Bosquez, Main. Tech

I HEREBY CERTIFY THIS IS A TRUE REPORT OF MY INSPECTION

Inspector Name Jean Alexandre	Ident. No. FL-826 NB-16597	Employed By Chubb	Ident. No. 30199789
---	--------------------------------------	-----------------------------	-------------------------------

D14-379
10/01/2000