

**APPENDIX C – MANUFACTURER'S/INSTALLING CONTRACTOR'S
REPORT FOR ASME CSD-1**

Certification and Reporting (CG-500) for Controls and Safety Devices
(This Form is a guideline and is not part of ASME CDS-1 1998.)

Unit Manufacturer

Name HURST BOILER & WELDING CO., INC.

Address 100 BOILERMAKER LANE, COOLIDGE, GA Zip 31738-3765

Telephone (229) 346-3545 Fax (229) 346-3874

Unit Identification (Boiler)

Manufacturer's Model # S4-G-350-150 Year Built 2021

ASME # _____ Nat. Bd. # 24938

UL # B85199251 AGA # _____

Jurisdiction _____

Steam

Max W.P. 150 PSI _____ psig

Min. Safety Valve Cap. 21636 _____ PPH

Hot Water

Max. W.P. N/A _____ psig

Max. Temp. N/A _____ ° F

Min. Safety Relief Valve Cap. _____ PPH or Btu

Boiler Unit Description (Type) 3 PASS WET BACK SCOTCH

If Modular (No. of Modules) _____

Boiler Unit Capacity (Output) _____

Burner

Manufacturer WEBSTER COMBUSTION Model JBE5G-75-K-U-MINI MK8-M.30M-UL

UL or AGA # C02533529 Serial # U140984A-01

Fuels (as Shipped) NATURAL GAS ONLY

Installation Location (if known)

Customer Name DISNEY / NSA TEXTILES


Address 1200 FACILITIES WAY


City ORLANDO State FL Zip 32836

Telephone _____ Fax _____

Control/Device	Manufacturer	Model	Operational Test Performed, Date
Operating Controls			
Low-Water Fuel Cutoff CW-120(a), CW-140	MCDONNELL MILLER	193-7B	10/12/2021
Forced Circulation CW-210(a)	N/A	N/A	
Steam Pressure CW-310(b)	AUTOFLAME	MM10008U	10/11/2021
Water Temperature CW-410(b)	N/A		
Safety Controls			
Low-Water Fuel Cutoff CW-120(a), CW-120(b) CW-130, CW-140	WARRICK	26NMB1B0	10/12/2021
Forced Circulation CW-210(b)	N/A		
High Steam Pressure Limit CW-310(c)	HONEYWELL	L4079B1041	10/12/2021
High Water Temperature Limit CW-410(b)	N/A		
Fuel Safety Shutoff Valve, Main CF-180(b)(2), CF-180(b)(3)	MAXON	300CMA11-AA112-BB22B0	10/11/2021
Pilot Safety Shutoff Valve CF-180(c)	ASCO	8040H008	10/11/2021
Atomizing Medium Switch CF-450(b)	N/A		
Combustion Air Switch CF-220	CLEVELAND	AFS-227-161	10/11/2021
High Gas Pressure CF-162	SIEMENS	QPH 31.150M00	10/12/2021
Low Gas Pressure CF-162	SIEMENS	QPH31.140M00	10/12/2021
Low Oil Pressure CF-450(a)	N/A		
High Oil Temperature CF-450(c)	N/A		
Low Oil Temperature CF-450(d)	N/A		
Purge Air Flow CF-210	CLEVELAND	AFS-227-161	10/11/2021
Flame Safeguard (Primary) CF-310, CF-320	AUTOFLAME	MK8 // MM80001	10/11/2021
Low Fire Start			
FLAME DETECTOR = AUTOFLAME MM60004/HSU = 10/11/2021			
Low Fire State Switch CF-610	AUTOFLAME	MK8 // MM80001	10/11/2021
Safety or Safety Relief Valve(s)			
CW-510, CW-520	KUNKLE	6010 JHEO1AAM	10/12/2021

Manufacturer KUNKLE Operational Test Performed, Date 10 / 12 / 2021
Model 6010 JHEO1AAM
Size 2"
Capacity 10818 (x2) PPH/Btu/hr

Representing Equipment Manufacturer, Name Richard Kevin Warren
Signature  Date 10-13-21

Representing Installing Contractor, Name Bernhard MCC
Signature  Date 10/17/21