

**DIVISION OF THE STATE FIRE MARSHALL
BUREAU OF FIRE PREVENTION
BOILER SAFETY PROGRAM**

This inspection is intended for your safety and the safety of the citizens of Florida. Your cooperation is greatly appreciated.

Boiler - Fired Pressure Vessel report of Inspection

Date Inspected 12/14/2022	Cert. Exp Date	Certificate Posted <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Follow Up Inspection <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Jurisdiction Number 096152	Nat'l Bd. No. 10306	Other No. AJH50.1270
Owner West Palm Beach Community Release Center			Owner Email jaketta.williams@fdc.myflorida.com		Kind of Inspection <input type="checkbox"/> Int <input checked="" type="checkbox"/> Ext	Cert Inspection <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Owner Street Address 261 Fairgrounds Rd			Owner City West Palm Bch		State FL	Zip 33411-3639
User Name - Object Location West Palm Beach Community Release Center			Nature Of Business Rehab Center		Object Location - County Palm Beach	
User Street Address 261 Fairgrounds Rd			User City West Palm Bch		State FL	Zip 33411-3639
Type Coil	ASME Code Stamp H	Year Built 1988	Manufacturer Weben-Jarco			
Specific Location in Plant Men's Work Release		Use Hot Water Supply	Fuel Natural Gas	Method of Firing Automatic	Pressure Gage Tested <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
Pressure Allowed 160	This Inspection 160 psi	Prev. Inspection 160 psi	Safety Relief Valves Set At 125 psi	Total Capacity 2070000 BTU/HR	Heating Surface and/or BTU 141.1 sq ft / 500000 BTU/hr	

Is condition of object such that a certificate may be issued?
(If No, explain fully under condition) ☐ Yes ☒ No

Hydro Test ☐ Yes ☒ No PSI DATE

CONDITIONS: With respect to the internal surface, describe and state location of any scale, oil or other deposits. Give location and extent of any corrosion and state whether active or inactive. State location and extent of any erosion, grooving, bulging, warping, cracking or similar condition. Report on any defective rivets, bowed, loose or broken stays. State condition of all tubes, tube ends, coils, nipples, etc. Describe any adverse conditions with respect to pressure gage, water column, gage glass, gage cocks, safety valves, etc. Report conditions of setting, linings, baffles, supports, etc. Describe any major changes or repairs made since last inspection.

Violations, 21 - 1.1 PRD INOPERABLE, 21 - 2.1.3 FLOW SWITCH DEVICE INOPERABLE. -- 21 - 1.1 PRD INOPERABLE -- 21 - 2.1.3 FLOW SWITCH DEVICE INOPERABLE

REQUIREMENTS: (List of Code Violations)

-21 - 1.1 PRD INOPERABLE - REF: NBIC PART 2, 2017 2.5.7.1 - IF A VALVE IS FOUND TO BE STUCK CLOSED, THE SYSTEM SHOULD IMMEDIATELY BE TAKEN OUT OF SERVICE UNTIL THE CONDITION CAN BE CORRECTED, UNLESS SPECIAL PROVISIONS HAVE BEEN MADE TO OPERATE ON A TEMPORARY BASIS (SUCH AS ADDITIONAL RELIEF CAPACITY PROVIDED BY ANOTHER VALVE.) THE OWNER SHALL BE NOTIFIED AND CORRECTIVE ACTION SUCH AS REPAIRING OR REPLACING THE INOPERABLE VALVE SHALL BE TAKEN.

-21 - 2.1.3 FLOW SWITCH DEVICE INOPERABLE - REF: NBIC PART 2, 2017 2.2.10.6 (H) ON FORCED CIRCULATION BOILERS, THE FLOW SENSING DEVICE SHALL BE TESTED TO VERIFY THAT THE BURNER WILL SHUT DOWN THE BOILER ON A LOSS OF FLOW.

Name and Title of Person To Whom Requirements Were Explained
Lt. Radigan

I HEREBY CERTIFY THIS IS A TRUE REPORT OF MY INSPECTION

Charles J. Schindler

Inspector Name	Ident. No.	Employed By	Ident. No.
Charles J. Schindler	FL-606 NB-11697	Liberty Mutual Insurance Co	30199794

D14-379

10/01/2000