


**DIVISION OF THE STATE FIRE MARSHALL
BUREAU OF FIRE PREVENTION
BOILER SAFETY PROGRAM**

This inspection is intended for your safety and the safety of the citizens of Florida. Your cooperation is greatly appreciated.

Boiler - Fired Pressure Vessel report of Inspection

Date Inspected 03/05/2024	Cert. Exp Date	Certificate Posted ☒ Yes ☐ No	Follow Up Inspection ☐ Yes ☒ No	Jurisdiction Number 003185	Nat'l Bd. No. 6142	Other No.
Owner Bardmoor Outpatient Center			Owner Email christopher.waincott@baycare.org		Kind of Inspection ☒ Int ☐ Ext	Cert Inspection ☐ Yes ☒ No
Owner Street Address 8787 Bryan Dairy Rd			Owner City Largo		State FL	Zip 33777-1251
User Name - Object Location Bardmoor Outpatient Center			Nature Of Business Medical Center		Object Location - County Pinellas	
User Street Address 8787 Bryan Dairy Rd			User City Largo		State FL	Zip 33777-1251
Type Fire Tube	ASME Code Stamp E	Year Built 2014	Manufacturer Chromalox			
Specific Location in Plant OPERATING ROOM		Use Process	Fuel Electric	Method of Firing Automatic	Pressure Gage Tested ☐ Yes ☒ No	
Pressure Allowed 100	This Inspection 100 psi	Prev. Inspection 100 psi	Safety Relief Valves Set At 100 psi	Total Capacity 423 LB/HR	Heating Surface and/or BTU 105000 BTU/hr	
Is condition of object such that a certificate may be issued? (If No, explain fully under condition)				Hydro Test ☐ Yes ☒ No		
CONDITIONS: With respect to the internal surface, describe and state location of any scale, oil or other deposits. Give location and extent of any corrosion and state whether active or inactive. State location and extent of any erosion, grooving, bulging, warping, cracking or similar condition. Report on any defective rivets, bowed, loose or broken stays. State condition of all tubes, tube ends, coils, nipples, etc. Describe any adverse conditions with respect to pressure gage, water column, gage glass, gage cocks, safety valves, etc. Report conditions of setting, linings, baffles, supports, etc. Describe any major changes or repairs made since last inspection. Inspection performed in accordance with the National Board Inspection Code and State of Florida regulations. Steam generating chamber inspected satisfactorily. Minor quantities of scale/sludge were observed. Code required safety controls and devices installed satisfactorily. No adverse conditions noted. Request certificate continuance.						
REQUIREMENTS: (List of Code Violations) None Required						
Name and Title of Person To Whom Requirements Were Explained Chris Waincott and Ernie Elvira						
I HEREBY CERTIFY THIS IS A TRUE REPORT OF MY INSPECTION 						
Inspector Name Victor Casada		Ident. No. FL-0516 NB-10971		Employed By Zurich American Insurance Co		Ident. No. 30199766

D14-379

10/01/2000